

FTP6 Testing and approval of pipe penetrations and cable transits for use in “A” class divisions (IMO FTP Code 2010 Annex 1 Part 3)

(Feb
2013)
(Rev.1
July 2015)

Regulation

IMO FTP Code 2010 Annex 1 Part 3 Appendix 1 item 1.13 reads:

The designs of the specimens proposed in this appendix are considered to reflect the worst case situations in order to provide maximum usefulness of the classifications to end-use applications. However, the Administration may accept or request special test arrangements which provide additional information required for approval, especially of those types of constructions which do not utilize the conventional components of horizontal and vertical divisions, e.g., where cabins may be of a modular type construction involving continuous connections between bulkheads, decks and ceilings.

Interpretation

Arrangement

“A”-class pipe penetrations and cable transits that are

- a) constructed without structural sleeves of minimum 3 mm thickness and minimum 60 mm length welded or bolted to the division; and/or
- b) constructed with removable, soft or intumescent filling material

are “those types of constructions which do not utilize conventional components of horizontal and vertical divisions” and are to be subject to additional testing and/or design criteria as described below:

Additional testing/design criteria

- Filling materials shall be adequately secured by bonded materials or mechanical means that cannot be removed without the use of tools in order to prevent damage by normal ship vibrations and pressures.
- ~~Prior to fire testing, t~~The pipe penetration/cable transit shall not have any visible openings. It shall not be possible to manually penetrate any part of the penetration with a ~~pointed implement such as a pen or a screwdriver.~~ 6 mm gap gauge, as described in paragraph 7.10 of Appendix 1 of Part 3 to Annex 1 of the 2010 FTP Code.

NOTE

1. This Unified Interpretation is to be uniformly implemented by IACS Societies for approvals granted on/ or after 1 January 2014.
2. Rev. 1 of this UI is to be uniformly implemented by IACS Societies for approvals granted on or after 1 January 2016.

FTP6 Approval

(cont)

Penetrations in structural divisions shall not impair the structural strength of the division. The structural make-up of the penetration is to be fully described so that its use and the need for additional stiffening for the division can be fully assessed.

| |
|--------------------|
| End of Document |
|--------------------|