

TÜRK LOYDU



TL-R F

Requirements Concerning Fire Protection

July 2019

These requirements are prepared by embedding related IACS Unified Requirements. In order to have consistency, the numbering of the requirements are kept as the same with related IACS Unified Requirements.

Unless otherwise specified, these Rules apply according to the implementation dates as defined in each requirement. See Rule Change Summary on TL website for revision details.

This latest edition incorporates all rule changes.

"General Terms and Conditions" of the respective latest edition will be applicable (see Rules for Classification and Surveys).

If there is a difference between the rules in English and in Turkish, the rule in English is to be considered as valid. This publication is available in print and electronic pdf version. Once downloaded, this document will become UNCONTROLLED. Please check the website below for the valid version.

<http://www.turkloydu.org>

All rights are reserved by Türk Loydu, and content may not be reproduced, disseminated, published, or transferred in any form or by any means, except with the prior written permission of **TL**.

TÜRK LOYDU

Head Office Postane Mah. Tersaneler Cad. No:26 Tuzla 34944 İSTANBUL / TÜRKİYE
Tel : (90-216) 581 37 00
Fax : (90-216) 581 38 00
E-mail : info@turkloydu.org
<http://www.turkloydu.org>

Regional Offices

Ankara Eskişehir Yolu Mustafa Kemal Mah. 2159. Sokak No : 6/4 Çankaya - ANKARA / TÜRKİYE
Tel : (90-312) 219 56 34
Fax : (90-312) 219 68 25
E-mail : ankara@turkloydu.org

İzmir Atatürk Cad. No :378 K.4 D.402 Kavalalılar Apt. 35220 Alsancak - İZMİR / TÜRKİYE
Tel : (90-232) 464 29 88
Fax : (90-232) 464 87 51
E-mail : izmir@turkloydu.org

Adana Çınarlı Mah. Atatürk Cad. Aziz Naci İş Merkezi No:5 K.1 D.2 Seyhan - ADANA / TÜRKİYE
Tel : (90- 322) 363 30 12
Fax : (90- 322) 363 30 19
E-mail : adana@turkloydu.org

CONTENTS

TL-R F15	Piping passing through dangerous zones
TL-R F20	Inert gas systems
TL-R F29	Non-sparking fans

TL- R F15 Piping passing through dangerous zones

F15.1 Ballast piping passing through cargo tanks and cargo oil pipes passing through segregated ballast tanks, as permitted by MARPOL Annex 1 Reg. 13F, are to comply with the following requirements.

F15.1.1 The pipes are to be of heavy gauge steel of minimum wall thickness according to the table hereunder with welded or heavy flanged joints the number of which is to be kept to a minimum.

Expansion bends only (not glands) are permitted in these lines within cargo tanks for serving the ballast tanks and within the ballast tanks for serving the cargo tanks.

Nominal diameter (mm)	Minimum wall thickness (mm)
50	6,3
100	8,6
125	9,5
150	11,0
200 and above	12,5

F15.2 The thicknesses shown in the above table refer to carbon steel.

F15.3 Connection between cargo piping and ballast piping referred to above is not permitted except for emergency discharge as specified in the Unified Interpretation to Reg. 1 (17) of MARPOL 73/78, Annex 1.

Nevertheless, provision may be made for emergency discharge of the segregated ballast by means of a connection to a cargo pump through a portable spool piece. In this case non-return valves should be fitted on the segregated ballast connections to prevent the passage of oil to the ballast tanks. The portable spool piece should be mounted in a conspicuous position in the pump room and a permanent notice restricting its use should be prominently displayed adjacent to it.

Shut-off valves shall be provided to shut off the cargo and ballast lines before the spool piece is removed.

F15.4 The ballast pump is to be located in the cargo pump room, or a similar space within the cargo area not containing any source of ignition.



TL- R F20 Inert Gas Systems

F20.1 General Requirements

F20.1.1 All types of inert gas systems are to comply with the following:

- .1 Plans in diagrammatic form are to be submitted for appraisal and should include the following:
 - details and arrangement of the inert gas generating plant including all control and monitoring devices;
 - arrangement of the piping system for distribution of the inert gas.
- .2 An automatic control capable of producing suitable inert gas under all service conditions is to be fitted.
- .3 Subsequent surveys are to be carried out at the intervals required by TL

F20.2 Requirements for All Systems on Tankers, including Chemical Tankers, to which SOLAS regulation II-2/4.5.5.1 applies

F20.2.1 An inert gas system complying with the applicable requirements of Ch. 15 of the FSS Code, as amended by MSC.367 (93), is to be fitted on tankers to which SOLAS regulation II-2/4.5.5.1 applies. In applying the applicable requirements of Ch. 15 of the FSS Code, any use of the word "Administration" therein is to be considered as meaning TL. The inert gas system is to be operated in accordance with SOLAS regulation II-2/16.3.3, as amended by MSC.365(93). In applying SOLAS regulation II-2/16.3.3.2, paragraph 2.2.1.2.4 of Ch. 15 of the FSS Code is to be complied with.

NOTES:

1. This requirement is applied on ships contracted for construction on or after 1 January 2016.
2. The "contracted for construction" date means the date on which the contract to build the vessel is signed between the prospective owner and the shipbuilder. For further details regarding the date of "contract for construction", refer to TL- PR 29.

F20.3 Additional Requirements for Nitrogen Generator Systems on Tankers, including Chemical Tankers, to which SOLAS regulation II-2/4.5.5.1 applies

F20.3.1 The following requirements apply where a nitrogen generator system is fitted on board as required by SOLAS regulation II-2/4.5.5.1. For the purpose, the inert gas is to be produced by separating air into its component gases by passing compressed air through a bundle of hollow fibres, semi-permeable membranes or adsorber materials.

F20.3.2 In addition to the applicable requirements of Ch. 15 of the FSS Code, as amended by MSC.367(93), the nitrogen generator system is to comply with SOLAS regulations II-2/4.5.3.4.2, 4.5.6.3 and 11.6.3.4.

F20.3.3 A nitrogen generator is to consist of a feed air treatment system and any number of membrane or adsorber modules in parallel necessary to meet paragraph 2.2.1.2.4 of Ch.15 of the FSS Code, as amended by MSC.367(93).

F20.3.4 The nitrogen generator is to be capable of delivering high purity nitrogen in accordance with paragraph 2.2.1.2.5 of Ch.15 of the FSS Code, as amended by MSC.367(93). In addition to paragraph 2.2.2.4 of Ch.15 of the FSS Code, as amended by MSC.367(93), the system is to be fitted with automatic means to discharge "off-spec" gas to the atmosphere during start-up and abnormal operation.

F20.3.5 The system is to be provided with one or more compressors to generate enough positive pressure to be capable of delivering the total volume of gas required by 2.2.1.2 of the FSS Code, as amended by MSC.367(93). Where two compressors are provided, the total required capacity of the system is preferably to be divided equally between the two compressors, and in no case is one compressor to have a capacity less than 1/3 of the total capacity required.

F20.3.6 The feed air treatment system fitted to remove free water, particles and traces of oil from the compressed air as required by 2.4.1.2 of Ch.15 of the FSS Code, as amended by MSC.367(93), is also to preserve the specification temperature.

F20.3.7 The oxygen-enriched air from the nitrogen generator and the nitrogen-product enriched gas from the protective devices of the nitrogen receiver are to be discharged to a safe location* on the open deck.

F20.3.8 In order to permit maintenance, means of isolation are to be fitted between the generator and the receiver.

^{*)} "safe location" needs to address the two types of discharges separately:

1. oxygen-enriched air from the nitrogen generator - safe locations on the open deck are:
 - outside of hazardous area;
 - not within 3m of areas traversed by personnel; and
 - not within 6m of air intakes for machinery (engines and boilers) and all ventilation inlets.
2. nitrogen-product enriched gas from the protective devices of the nitrogen receiver - safe locations on the open deck are:
 - not within 3m of areas traversed by personnel; and
 - not within 6m of air intakes for machinery (engines and boilers) and all ventilation inlets/outlets.

F20.4 Nitrogen /Inert Gas Systems Fitted for Purposes other than Inerting Required by SOLAS Reg. II-2/4.5.5.1 and 4.5.5.2

F20.4.1 This section applies to systems fitted on oil tankers, gas tankers or chemical tankers to which SOLAS regulations II-2/4.5.5.1 and 4.5.5.2 do not apply.

F20.4.2 Paragraphs 2.2.2.2, 2.2.2.4, 2.2.4.2, 2.2.4.3, 2.2.4.5.1.1, 2.2.4.5.1.2, 2.2.4.5.4, 2.4.1.1, 2.4.1.2, 2.4.1.3, 2.4.1.4, 2.4.2.1 and 2.4.2.2 of Ch.15 of the FSS Code, as amended by MSC.367(93), as applicable apply to the systems.

F20.4.3 The requirements of section F20.3 apply except paragraphs F20.3.1, F20.3.2, F20.3.3 and F20.3.5.

F20.4.4 Materials used in inert gas systems are to be suitable for their intended purpose in accordance with the Rules of TL.

F20.4.5 All the equipment is to be installed on board and tested under working conditions to the satisfaction of the Surveyor.

F20.4.6 The two non-return devices as required by paragraph 2.2.3.1.1 of Ch.15 of the FSS Code, as amended by MSC.367(93) are to be fitted in the inert gas main. The non-return devices are to comply with 2.2.3.1.2 and 2.2.3.1.3 of Ch.15 of the FSS Code, as amended by MSC.367(93); however, where the connections to the cargo tanks, to the hold spaces or to cargo piping are not permanent, the non-return devices required by paragraph 2.2.3.1.1 of Ch.15 of the FSS Code, as amended by MSC.367(93) may be substituted by two non-return valves.

TL- R F29 Non-sparking fans

F29.1 Introduction

A fan is considered as non-sparking if in either normal or abnormal conditions it is unlikely to produce sparks.

F29.2 Design criteria

F29.2.1 The air gap between the impeller and the casing shall be not less than 0,1 of the shaft diameter in way of the impeller bearing but not less than 2 mm. It need not be more than 13 mm.

F29.2.2 Protection screens of not more than 13 mm square mesh are to be fitted in the inlet and outlet ventilation openings on the open deck to prevent the entrance of objects into the fan housing.

F29.3 Materials

F29.3.1 The impeller and the housing in way of the impeller are to be made of alloys which are recognised as being spark proof by appropriate test.

F29.3.2 Electrostatic charges both in the rotating body and the casing are to be prevented by the use of antistatic materials. Furthermore, the installation on board of the ventilation units is to be such as to ensure the safe bonding to the hull of the units themselves.

F29.3.3 Tests may not be required for fans having the following combinations:

- (i) impellers and/or housings of nonmetallic material, due regard being paid to the elimination of static electricity,
- (ii) impellers and housings of non-ferrous materials,
- (iii) Impellers of aluminium alloys or magnesium alloys and a ferrous (including austenitic stainless steel) housing on which a ring of suitable thickness on non-ferrous materials is fitted in way of the impeller,
- (iv) any combination of ferrous (including austenitic stainless steel)impellers and housings with not less than 13 mm tip design clearance.

F29.3.4 The following impellers and housings are considered as sparking and are not permitted:

- (i) impellers of an aluminium alloy or magnesium alloy and a ferrous housing, regardless of tip clearance,
- (ii) housing made of an aluminium alloy or a magnesium alloy and a ferrous impeller, regardless of tip clearance,
- (iii) any combination of ferrous impeller and housing with less than 13 mm design tip clearance.

F29.3.5 Type tests on the finished product are to be carried out in accordance with the requirements of TL or an equivalent national or international standard.

